

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
www.accuratetesting.com
info@accuratetesting.com

Certificate of Analysis

Order No.: **2021110443**

Page: 1 of 1

Southside Water & Sewer
P. O. Box D
Sandpoint, ID 83864

Project: SOC Report PWS# 1090131

Date Received: 11/23/2021 10:00

Sample: **1**
Location: Wellhouse Manifold
Sample Type: Plant Tap

Matrix: Drinking Water
D/T Collected: 11/23/2021 08:17
Collected by: Brad White

Analyte	Result	Unit	Method	PQL	Analysis Date	Analyst
Simazine	ND	ug/L	EPA 525.2	0.07	12/01/21	ANA
Glyphosate	ND	ug/L	EPA 547	5	11/29/21	ANA
2,4-D	ND	ug/L	EPA 515.4	0.1	12/01/21	ANA
Picloram	ND	ug/L	EPA 515.4	0.1	12/07/21	ANA

If the RESULT is 'ND' (Not Detected) or 'Absent', that means the concentration is less than the PQL (Practical Quantitation Limit for this method).

Comments:



Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 12/14/21